



OXYFOOD LABORATORY (OPC) PVT. LTD.

NABL Accredited Laboratory as per ISO/IEC 17025:2017

● WATER ● FOOD PRODUCTS ● SOIL TESTING

Sr.No. 46/2/1, Anushila Residency, 1st Floor, Above Shambhavi Hotel, Sangharsh chowk, Chandan Nagar, Kharadi, Pune - 411014. Mob No. 9730649301 / 7020390347 Website: <http://oxyfoodlaboratory.com> E-mail: oxyfoodlab@gmail.com



TC-14654

Water Test Report

ULR No: TC146542500000559F


Date of Report: 11/04/2025

Customer Name & Address	AQUAMARINE GLOBAL SOLUTIONS Sr. No.39, Matenagar, Lane No5, Opp.Niramay, Hospital, Wadgaon Sheri, Pune- 411014, Maharashtra India.		
Site Name	Alard Public School , Marunji Pune.		
Name Of Sample	Softner Treated	Sample Code	OFL/080420250559
Discipline	Chemical	Group	Water
Sample Collected By	Customer	Sample Received On	08/04/2025
Sample Container	Plastic Bottle	Start of Analysis	08/04/2025
Sample Quantity	1 lit	End of Analysis	11/04/2025
Test Requirement	As per IS 10500:2018 Drinking water Specifications		

Analysis Report:-

Sr.No	Test Parameters	Results	Units	Limits as IS :10500:2018		Test Methods
				Desirable	Permissible	
1.	pH	7.60	--	6.5 to 8.5	6.5 to 8.5	IS 3025 (Part-11)
2.	Total Dissolved Solid	558.0	mg/l	500 max	2000 max	IS 3025 (Part -16)
3.	Alkalinity	294.01	mg/l	200 max	600 max	IS 3025 (Part- 23)
4.	Electrical Conductivity	1060.0	µS/cm	--	--	IS 3025(part-14)
5.	Chloride	80.97	mg/l	250 max	1000 max	IS 3025 (Part -32)
6.	Total Hardness	8.00	mg/l	200 max	600 max	IS 3025 (Part 21)
7.	Color	< 5	CU	max 5	max 15	IS 3025 (Part-4)
8.	Odour	Agreeable	--	Agreeable	Agreeable	IS 3025 (Part-5)
9.	Turbidity	0.12	NTU	1 max	5 max	IS 3025 (Part 10)
10.	Calcium	1.60	mg/l	75 max	200 max	IS 3025 (Part-40)
11.	Magnesium	0.97	mg/l	30max	100 max	IS 3025 (Part-46)

Prepared By



Mrs. Gouri Dhokale
AUTHORISED SIGNATORY

Conditions of reporting:-1.Above result pertain only to the sample tested in laboratory.2.This report in full for part shall not be published advertised, unless prior has been secured.3. Perishable Sample Discard Immediately after testing & Non Perishable samples will be stored for 15 days after testing.



OXYFOOD LABORATORY (OPC) PVT. LTD.

ISO 9001:2015

● WATER ● FOOD PRODUCTS ● SOIL TESTING

Sr.No. 46/2/1, Anushila Residency, 1st Floor, Above Shambhavi Hotel, Sangharsh chowk, Chandan Nagar, Kharadi, Pune - 411014. Mob No. 9730649301 / 7020390347 Website: <http://oxyfoodlaboratory.com> E-mail: oxyfoodlab@gmail.com

Water Test Report


Date of Report:-11/04/2025

Customer Name & Address	AQUAMARINE GLOBAL SOLUTIONS Sr. No.39, Matenagar, Lane No5, Opp. Niramay, Hospital, Wadgaon Sheri, Pune- 411014, Maharashtra India.		
Site Name	Alard Public School, Marunji Pune.		
Name Of Sample	Softner Treated	Sample Code	OFL/080420250559
Discipline	Chemical	Group	Water
Sample Collected By	Customer	Sample Received On	08/04/2025
Sample Container	Plastic Bottle	Start of Analysis	08/04/2025
Sample Quantity	1 lit	End of Analysis	11/04/2025
Test Requirement	As per IS 10500:2018 Drinking water Specifications		


Analysis Report:-

Sr.No	Test Parameters	Results	Units	Limits as IS :10500:2018		Test Methods
				Desirable	Permissible	
12.	Sulphate	15.10	mg/l	200 max	400 max	IS 3025 (Part 24)
13.	RFC	< 0.1	mg/l	0.2 max	1 max	IS 3025 (Part-26)
14.	Silica	4.00	mg/l	--	--	IS : 3025 (Part 35)
15.	Total Bacterial Count	11	cfu/ml	--	--	IS 1622 Reaf : 2019
16.	E.Coli	Present	Absent in 100 ml	Absent/100 ml		IS 15185-2016
17.	Coliform	Present	Absent in 100 ml			IS 15185-2016

Remark:-Based upon the results of above parameters the sample does not conforms to the standard.


Prepared By




Mrs. Gouri Dhokale
AUTHORISED SIGNATORY

..... END

Conditions of reporting:-1.Above result pertain only to the sample tested in laboratory.2.This report in full for part shall not be published advertised, unless prior has been secured.3. Perishable Sample Discard Immediately after testing & Non Perishable samples will be stored for 15 days after testing.